



1. P.E. CELL, IF REQUIRED
2. LUMINARIES
250 WATT METAL HALIDE W/CUT-OFF LENSE
3. ALUMINUM TAPERED ELLIPTICAL ARM
4. EXTRUDED ALUMINUM MOUNTING PLATE
5. POLE FOUNDATION PER THE VILLAGE STANDARD
6. MANHOLE WITH ALUMINUM COVER
LOCATED FACING AWAY FROM CURB.
7. TOP OF FOUNDATION SHALL BE 1-1/2" ABOVE TOP OF
CURB OR EDGE OF PAVEMENT UNLESS OTHERWISE
APPROVED BY THE VILLAGE ENGINEER.



VILLAGE OF WHEELING
ENGINEERING DIVISION
2 COMMUNITY BOULEVARD
WHEELING, IL 60090
WWW.WHEELINGIL.GOV

STREET LIGHT STANDARD

VILLAGE OF WHEELING SPECIFICATIONS AND DETAILS		REVISIONS	
FILE LOCATION		S.W.	11-16-01 AUTOCAD FILE
N:\ENGINEERING\STANDARDS\STREETLIGHTING		K.R.G.	9-11-06 AUTOCAD FILE